

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-1394:104 Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Apollo Fire Detectors, 1749 E. Highwood, Pontiac MI 48340
Contact: Robert Skaggs (810) 332-3900

DESIGN: Model 55000-650 photoelectric type smoke detector with Model 45681-210 mounting base. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 17 - 28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detector and mounting base for use with separately listed compatible fire alarm control units.

04-17-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 15, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager